



Jim Doyle, Governor Jack L. Fischer, A.I.A., Secretary

P.O. Box 2658

March 17, 2008

TUF-TITE TED MEYERS 1200 FLEX CT LAKE ZURICH IL 60047

Re: Description: SEWAGE TANK COVERS, LIDS, RISERS

Manufacturer: TUF-TITE

Product Name: SEPTIC TANK RISER AND LID

Model Number(s): 24" RISER AND LID

Product File No: 20080159

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84. Wisconsin Administrative Code, and Chapters 145 and 160. Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2013.

This approval is contingent upon compliance with the following stipulation(s):

- The manhole cover must be secured to the riser using screws which are not standard or phillips head to be considered an effective locking device.
- Joints between riser sections shall be seal with butyl mastic sealant and secured with a minimum of four screws.

To better clarify this plumbing product, on 3/17/08 the product type description has been changed from 'sewage tank apparatus' (STA) to 'sewage tank cover and lid', (STCOVR). See on-line search:

Manufacturer's search: http://commerce.wi.gov/php/sb-ppalopp/manuf_alpha_list.php Product type (alpha) search: http://comwebd/php/sb-ppalopp/prodcode alpha list.php

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST Engineering Consultant--Plumbing Product Reviewer Commerce; Safety & Buildings Div. PO Box 2658 201 W Washington Ave. Madison WI 53703-2658

Phone: 608-266-0955: Fax: 608-283-7456 E-mail: Jean.MacCubbin@wisconsin.gov

SBD-10564-E (N.10/97) File Ref: 08015901.DOC